



HWA-HSING



ATTESTATION OF CONFORMITY

Release No.: 7.0 (2022)

Attestation No.: HS5200-221122JH05-1-EU-01
 Issued To: Upower Electric Co., LTD
 Applicant Address: Room 401, A Building Huafeng Intelligence Valley-Yuanshan Hi-Tech Park, No.62 Yinhe Road, He'ao Community, Yuanshan Street, Longgang District, Shenzhen, China
 Product(s): HYBRID INVERTER
 Brand(s): CAN POWER
 Model(s): UHC-4KT,UHC-5KT,UHC-6KT,UHC-8KT,UHC-10KT,UHC-12KT,UHC-10KT-40, UHC-12KT-40,UHC-15KT,UHC-20KT
 Power Characteristics (UHC-20KT): Rated DC input voltage: DC 620V 30A*2
 Rated AC output voltage: 3L/N/PE, 220/380V; 230/400V; 240/415V~33.5A

We, Hwa-Hsing (Dongguan) Testing Co., Ltd.,

Declare that the submitted sample of the above has been tested for CE marking according to following standard(s) of the European Directive:

- Radio Equipment Directive (RED) 2014/53/EU

Essential Requirement	Standards	Report No.
Article 3.1(a) safety	IEC/EN 62109-1:2010 IEC/EN 62109-2:2011	WT223202796
Article 3.1(b) EMC	EN 55011:2016/A2:2021; CISPR 11:2015/AMD2:2019; EN IEC 61000-6-1:2019; IEC 61000-6-1:2016 EN IEC 61000-6-2:2019; IEC 61000-6-2:2016 EN IEC 61000-6-3:2021; IEC 61000-6-3:2020 EN IEC 61000-6-4:2019; IEC 61000-6-4:2018 EN IEC 61000-3-2:2019+A1:2021; IEC 61000-3-2:2018/AMD1:2020; EN 61000-3-12:2011; IEC 61000-3-12:2011+AMD1:2021; EN IEC 61000-3-11:2019; IEC 61000-3-11:2017 EN 61000-3-3:2013/A2:2021; IEC 61000-3-3:2013/AMD2:2021	221122JH05-1-RE-EU-01

The quoted test report shows that the product conforms to the accepted standard and can be presumed to meet the basic requirements; In addition, please refer to the customer's sub-certificate statement for the model corresponding to the test report and the sub-certificate.

This ATTESTATION does not imply assessment of the production of the product.



Scott He

Scott He
Dec. 07, 2022

This document shall not be reproduced, except in full, without the written approval of Hwa-Hsing (Dongguan) Testing Co., Ltd. Information given in this document, are related to the tested specimen of the described electrical sample.

Lab: Hwa-Hsing (Dongguan) Testing Co., Ltd.

Address: No.101, Bld N1, Yuyuan 2Rd, Yuyuan Industrial Park, HuangJiang Town, Dongguan, China

Tel: +86 769 83078199

E-Mail: customerservice.dg@hwa-hsing.com

Web: www.hwa-hsing.com